Please read and save this Repair Parts Manual. Read this manual and the General Operating Instructions carefully before attempting to assemble, install, operate or maintain the product described. Protect yourself and others by observing all safety information. The Safety Instructions are contained in the General Operating Instructions. Failure to comply with the safety instructions accompanying this product could result in personal injury and/or property damage! Retain instructions for future reference. AMT reserves the right to discontinue any model or change specifications at any time without incurring any obligation.

©2020 AMT Pump Company, A Subsidiary of The Gorman-Rupp Company, All Rights Reserved.

Periodic maintenance and inspection is required on all pumps to ensure proper operation. Unit must be clear of debris and sediment. Inspect for leaks and loose bolts. Failure to do so voids warranty.

# Centrifugal Pumps

## Cast Iron, Bronze and Stainless Steel Models

A Gorman-Rupp Company

Refer to pump manual 1808-634-00 for General Operating and Safety Instructions.

## DESCRIPTION

AMT Solids Handling Centrifugal pumps are designed for continuous-duty low pressure OEM, Industrial/Commercial and general service applications including circulation, chemical processing, dirty water and liquid transfer. Self-cleaning impeller prevents clogging and handles solids of 1/8" diameter. Pumps are designed to handle liquids with solids content or dissolved solids and debris. Continuous duty, 3450 RPM, 56J frame motors. Discharge port can be rotated in 90º increments to accommodate specific applications. Casing working pressure to 75 psi (517 kPa). These are manual units; no controls are supplied. For use with nonflammable, nonabrasive liquids compatible with pump component materials.

### CAST IRON UNITS

Pump construction is Cast Iron casing and adapter. Investment Cast 300 Series Stainless Steel impeller. Buna N mechanical shaft seal with carbon and ceramic wear faces. O-ring casing seal. Handles liquids from 40º to 180º F (4º to 82º C).

### BRONZE UNITS

Pump construction is Cast Bronze casing and adapter. Investment Cast 300 Series Stainless Steel impeller. Viton® mechanical shaft seal with carbon and ceramic wear faces. O-ring casing seal. Handles liquids from 40º to 200º F (4º to 93º C).

### STAINLESS STEEL UNITS

Pump construction is Investment Cast 300 Series Stainless Steel casing, adapter and impeller. Viton® mechanical shaft seal with carbon and ceramic wear faces. O-ring casing seal. Handles liquids from 40º to 200º F (4º to 93º C).

## MAINTENANCE

**⚠WARNING**

***Make certain that unit is disconnected from power source before attempting to service or remove any components!***

## MECHANICAL SEAL REPLACEMENT:

Refer to Figures 1, 2, & 3.

**IMPORTANT:** Always replace both seal seat (Ref. No. 5) and seal head (Ref. No. 6) to ensure proper mating of components! Also, impeller seal (Ref. No. 9) should be replaced anytime impeller fastener (Ref. No. 10) has been removed.

1. Remove fasteners (Ref. No. 13) connecting casing (Ref. No. 12) to adapter (Ref. No. 4).
2. Remove casing.

**⚠ CAUTION**

***Care should be taken not to "pinch" or "shave" casing seal (Ref. No. 11) between adapter and casing.***

3. Use a box and/or socket wrench to remove impeller fastener. Remove impeller seal and impeller (Ref. No. 8).

**IMPORTANT:** Care should be taken to ensure that the same number and thickness of shim washers (Ref. No. 7) are replaced behind impeller that were removed. Shim washers are located directly behind impeller and become loose as impeller is removed.

4. Seal head can now be pulled from shaft.
5. Pry seal seat from adapter (Ref. No. 4).

**⚠ CAUTION**

***The precision lapped faces on mechanical seal are easily damaged. Handle your replacement seal carefully. Do not touch polished seal faces.***

**IMPORTANT:** Be sure that shaft shoulder does not damage polished face (see Figure 1).

6. Thoroughly clean all surfaces of seal seat cavity in adapter.
7. Using a clean cloth, wipe shaft and shaft sleeve to make certain that both parts are perfectly clean.
8. Wet the rubber portion of new seal seat with a light coating of soapy water. While wearing clean gloves or using a clean light rag, press seal seat squarely into adapter recess, use cardboard washer (usually supplied with new seal), place over polished surface and use a piece of pipe or dowel rod to press in firmly, but gently. Avoid scratching polished face.
9. Dispose of cardboard washer. Check again to see that polished surface is free of dirt and all other foreign particles and that it has not been scratched or damaged.
10. Wet inside rubber portion of new seal head with a light coating of soapy water. Slide head onto motor shaft with sealing surface facing seal seat. (See Figure 2).
11. Replace any impeller shims (Ref. No. 7) which may have been removed in disassembly. (See “Shim Adjustment” below.)
12. Screw impeller back into place, tightening until it is against shaft shoulder.
13. Replace impeller seal and fastener and tighten until snug.
14. Remount casing and casing seal on adapter.




Figure 1 – Seal Replacement

# Centrifugal Pumps

## SHIM ADJUSTMENT

1. When installing a replacement adapter (Ref. No.4), impeller (Ref. No. 8), or casing (Ref. No. 12) it may be necessary to vary number of impeller shims (Ref. No. 7) that will be required. This is easily done by adding one shim more than was removed and reassembling pump as described in “Mechanical Seal Replacement” section.

**NOTE:** When adding or removing shims, it is best to proceed with a 0.010" increment each time. While tightening unit together turn shaft; feel for shaft seizing. If shaft begins to seize before fasteners are completely tight, disassemble pump and remove one shim and repeat assembly.

2. Once having added one shim more than original, ensure that casing and adapter are firmly fitted (check fasteners Ref. No. 13). When pump shaft turns freely, add shims until it does strike, then remove a 0.010" shim. This should allow proper clearance.
3. Proper running clearance for impeller should be as close as possible to volute without striking; maximum clearance is 1/32" (0.032").
4. Follow above procedure until proper clearance is obtained. This will ensure maximum performance.

# *For Repair Parts contact dealer where pump was purchased.*

*Please provide following information:*
-Model Number
-Serial Number (if any)
Part description and number as shown in parts list




**Figure 2 – Repair Parts Illustration**

# Repair Parts List

**(ODP Models are for reference ONLY)**

| Ref. No. | Description | | Part Number for Models: 368A (1/3HP) - | 368B (1/2HP) 368C (1/2HP) | 370B (1/2HP) 370F (1/2HP) | **370A (3/4HP) 370C (3/4HP)** | Qty. |
|---|---|---|---|---|---|---|---|
| 1 | Motor | -1 Phase TEFC | 1626-300-00 | 1626-301-00 | 1626-301-00 | 1626-302-00 | 1 |
| | | -3 Phase TEFC | - | 1626-307-00 | 1626-307-00 | 1626-308-00 | 1 |
| 3 | Fastener | | Incl. w/Ref 4 | Incl. w/Ref 4 | Incl. w/Ref 4 | Incl. w/Ref 4 | 4 |
| 4 | Adapter Kit | -Cast Iron | 3680-035-95 | 3680-035-95 | 3690-035-95 | 3690-035-95 | 1 |
| | | -Bronze | 3680-036-97 | 3680-036-97 | 3690-036-97 | 3690-036-97 | 1 |
| | | -Stainless Steel | 3680-034-98 | 3680-034-98 | 3690-034-98 | 3690-034-98 | 1 |
| | (includes Ref. Nos. 3 & 4) | | | | | | |
| 5 & 6 | Shaft Seal Assembly | -Buna N | 1640-161-90 | 1640-161-90 | 1640-161-90 | 1640-161-90 | 1 |
| | | -Viton® | 1640-161-91 | 1640-161-91 | 1640-161-91 | 1640-161-91 | 1 |
| 7 | Impeller Shim Set | | 1806-044-90 | 1806-044-90 | 1806-044-90 | 1806-044-90 | 1 |
| 8 | Impeller Kit | | 368A-015-98 | 3680-015-98 | 370B-013-98 | 3701-013-98 | 1 |
| | (includes Ref. Nos. 7, 8 & 10) | | | | | | |
| 9 | Impeller Seal | -Buna N | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| | | -Viton® | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| 10 | Impeller Fastener | | 1784-001-00 | 1784-001-00 | 1784-001-00 | 1784-001-00 | 1 |
| 11 | Casing Seal | -Buna N | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| | | -Viton® | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| 12 | Casing Kit | -Cast Iron | 3680-002-95 | 3680-002-95 | 3700-002-95 | 3700-002-95 | 1 |
| | | -Bronze | 3680-003-97 | 3680-003-97 | 3700-003-97 | 3700-003-97 | 1 |
| | | -Stainless Steel | 3680-001-98 | 3680-001-98 | 3700-001-98 | 3700-001-98 | 1 |
| | (includes Ref. Nos. 12, 13 & 14) | | | | | | |
| 13 | Fastener | | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | 5 |
| 14 | 1/8" NPT Pipe Plug | | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | 1 |
| KIT | O-Ring Seal Kit | -Buna N | 3680-300-90 | 3680-300-90 | 3690-300-90 | 3690-300-90 | 1 |
| | | -Viton® | 3680-300-91 | 3680-300-91 | 3690-300-91 | 3690-300-91 | 1 |
| | (includes Ref. Nos. 9 & 11) | | | | | | |

# *For Repair Parts contact dealer where pump was purchased.*

*Please provide following information:*
-Model Number
-Serial Number (if any)
Part description and number as shown in parts list




**Figure 3 – Repair Parts Illustration**

# Repair Parts List

**(ODP Models are for reference ONLY)**

| Ref. No. | Description | | Part Number for Models: 370E (1HP) 370D (1HP) | 369C (1HP) 369F (1HP) | 369A (1-1/2HP) 369B (1-1/2HP) | 369D (2HP) 369E (2HP) | Qty. |
|---|---|---|---|---|---|---|---|
| 1 | Motor | -1 Phase TEFC | 1626-303-00 | 1626-303-00 | 1626-304-00 | 1626-305-00 | 1 |
| | | -3 Phase TEFC | 1627-309-00 | 1627-309-00 | 1627-310-00 | 1627-311-00 | 1 |
| 3 | Fastener | | Incl. w/Ref 4 | Incl. w/Ref 4 | Incl. w/Ref 4 | Incl. w/Ref 4 | 4 |
| 4 | Adapter Kit | -Cast Iron | 3690-035-95 | 3690-035-95 | 3690-035-95 | 3690-035-95 | 1 |
| | | -Bronze | 3690-036-97 | 3690-036-97 | 3690-036-97 | 3690-036-97 | 1 |
| | | -Stainless Steel | 3690-034-98 | 3690-034-98 | 3690-034-98 | 3690-034-98 | 1 |
| | (includes Ref. Nos. 3 & 4) | | | | | | |
| 5 & 6 | ✧Shaft Seal Assembly | -Buna N | 1640-161-90 | 1640-161-90 | 1640-161-90 | 1640-161-90 | 1 |
| | | -Viton® | 1640-161-91 | 1640-161-91 | 1640-161-91 | 1640-161-91 | 1 |
| 7 | Impeller Shim Set | | 1806-044-90 | 1806-044-90 | 1806-044-90 | 1806-044-90 | 1 |
| 8 | Impeller Kit | | 3700-013-98 | 369C-013-98 | 3691-013-98 | 3690-013-98 | 1 |
| | (includes Ref. Nos. 7, 8 & 10) | | | | | | |
| 9 | Impeller Seal | -Buna N | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| | | -Viton® | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| 10 | Impeller Fastener | | 1784-001-00 | 1784-001-00 | 1784-001-00 | 1784-001-00 | 1 |
| 11 | Casing Seal | -Buna N | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| | | -Viton® | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | Incl. w/Ref KIT | 1 |
| 12 | Casing Kit | -Cast Iron | 3700-002-95 | 3690-002-95 | 3690-002-95 | 3690-002-95 | 1 |
| | | -Bronze | 3700-003-97 | 3690-003-97 | 3690-003-97 | 3690-003-97 | 1 |
| | | -Stainless Steel | 3700-001-98 | 3690-001-98 | 3690-001-98 | 3690-001-98 | 1 |
| | (includes Ref. Nos. 12, 13 & 14) | | | | | | |
| 13 | Fastener | | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | 5 |
| 14 | 1/8" NPT Pipe Plug | | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | Incl. w/Ref 12 | 1 |
| KIT | O-Ring Seal Kit | -Buna N | 3690-300-90 | 3690-300-90 | 3690-300-90 | 3690-300-90 | 1 |
| | | -Viton® | 3690-300-91 | 3690-300-91 | 3690-300-91 | 3690-300-91 | 1 |
| | (includes Ref. Nos. 9 & 11) | | | | | | |

A Gorman-Rupp Company

AMT Pump Company
(herein "AMT")
400 Spring Street
Royersford, PA 19468
Phone: (610) 948-3800
Fax: (610) 948-5300
www.amtpump.com

ipt PUMPS BY GORMAN-RUPP

## General Information

***SALES POLICY:*** AMT products are sold through our established Distributors. We do not sell direct to the consumer or organization not entitled to trade recognition. Therefore, possession of our catalogs and/or price list(s) does not infer an offer to sell.

***MINIMUM ORDER:*** We appreciate your order, however, all orders are subject to a minimum $35.00 net invoice charge (excluding freight). This applies to all pump and parts purchase orders.

***PRICES:*** Prices are subject to change without notice. All orders accepted are subject to prices in effect at time of shipment.

***PAYMENT TERMS:*** Terms, upon establishment of credit, are Net 30 days. Past due accounts may be subject to a service charge of 1.5% per month. Domestic or assignable letter of credit is required for all export trade.

***PAST DUE ACCOUNTS:*** AMT reserves the right to withhold open account shipments on any past due account. Invoices are considered past due after thirty (30) days. In the interest of sound business, all orders are subject to approval of the Credit Department.

***SHIPPING INSTRUCTIONS:*** All shipments will be made F.O.B. the factory. Where instructions for shipment do not appear on the order, the shipment will be made according to our best judgment. Full risk of loss (including transportation delays and losses) shall pass to the customer upon delivery of the products to the carrier at the F.O.B. point. When loss or delay occurs, primary responsibility for tracing rests with the customer. When there is LOSS or APPARENT VISIBLE DAMAGE to a shipment, when tendered for delivery, *DO NOT* give the carrier a clear receipt. Note such damage on the carrier's delivery receipt and *HAVE THE DRIVER SIGN THE RECEIPT.*

***PRODUCT REVISIONS:*** AMT reserves the right to discontinue, change or improve its products or any portions thereof without being obligated to provide such a change or improvement for units sold and/or shipped prior to such a change or improvement.

***LEAD TIME:*** Products designated "Quick Ship Product", also referred to as "QSP" will normally be shipped within 24 hours of receipt of a non-cancellable purchase order. Only limited quantities of "QSP" pumps are available.

***STANDARD LEAD TIME:*** Lead time is two weeks for all non "QSP" product. AMT reserves the right to revise lead times as required due to availability of materials and all other causes beyond our control.

***VIP SHIPMENT:*** Select AMT and IPT branded pumps are available for next day shipment for non-QSP (Quick Ship Products) items and subjected to a specific model surcharge per unit noted in the respective price book. Requires calling for availability, confirmation and a non-cancellable purchase order or credit card payment prior to shipment. The expedited shipping charges are an additional cost added separately from the VIP charges per item. AMT reserves the right to revise lead times as required due to availability of materials and all other causes beyond our control. QSP quantities are limited as determined by AMT.

ALL purchase orders must be submitted via hard copy sent to AMT customer service department by fax, EDI or e-mail.

***RETURN GOODS POLICY:*** Goods shall not be returned without a return goods authorization number (RGA) issued by AMT customer service. The RGA number must be listed on the packing list. Only current model and part numbers with a valid date code may be returned (within one year from date of purchase). **A 20% restocking and packaging charge will apply to all returns. All shipping charges must be pre-paid. No exceptions.**

***ORDER CHANGES BY CUSTOMER:*** Orders in process may not be changed except with written consent and may be subject to special charges.

## 12 Month Limited Warranty

***EXTENT AND DURATION OF LIMITED WARRANTY***

**Coverage:** AMT Pump Company (herein "AMT") or IPT Pumps by Gorman-Rupp (herein "IPT") or Gorman-Rupp Industries Division of the The Gorman-Rupp Company, Patterson, or the Gorman-Rupp Company (herein referred to as "G-R Unit) each individually warrants that its products and parts shall be free from defects in material and workmanship for twelve (12) months from the date of purchase by the original end user when installation is made and maintenance is performed in accordance with G-R Unit's recommendations. Wear and tear resulting from use and items normally consumed in use are not covered.

***EXCEPTIONS***

( A ) This Limited Warranty shall not apply to mechanical seals in AMT or IPT pumps and the following products and parts: engines, motors, trade accessories and all other products, components, parts and materials not manufactured by the G-R Units. These items may, however, be covered by the warranties of their respective manufacturers. ( B ) This warranty does not extend to or apply to any unit which has been repaired or altered at any place other than by a G-R Unit, or by persons not expressly approved by a G-R Unit to make repairs or alterations, nor to any unit the serial number, model number or identification of which has been removed, defaced or altered. ( C ) This warranty does not extend to any product manufactured by a G-R Unit, which has been subjected to mis-use, neglect, accident, improper installation, or use in violation of instructions furnished by a G-R Unit. ( D ) Pump Kits: This warranty does not extend to any product sold by a G-R Unit unassembled as a Pump Kit. Pump Kits are warranted against defects in material and workmanship for 60 days from the date of shipment from a G-R Unit. Any Pump Kit parts deemed defective by a G-R Unit will be replaced free of charge within 60 days of shipment. Pump Kits are not returnable for credit.

***LIMITATIONS***

**THE G-R UNITS' SOLE AND EXCLUSIVE WARRANTY WITH RESPECT TO THEIR PRODUCTS AND PARTS IS THIS LIMITED WARRANTY. THIS LIMITED WARRANTY IS IN LIEU OF ALL OTHER EXPRESS AND/OR IMPLIED WARRANTIES, INCLUDING IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR PARTICULAR PURPOSE.**

***EXCLUSIVE REMEDY AND DAMAGES***

The sole and exclusive remedy for breach of this Warranty by a G-R Unit and the entire extent of its liability for such breach or for damages arising from the use of the products and parts covered under this Limited Warranty, shall be as follows:

1. **Repair or Replacement:** If inspection shows that any G-R Unit product or part covered under this Limited Warranty is defective in materials or workmanship, the G-R Unit shall repair or replace the defective or non-conforming product or part without charge, whichever the G-R Unit chooses. You must have properly maintained and used the product or part claimed to be defective in accordance with the maintenance schedule or manual, which comes with the product. No allowance will be made for labor, installation, removal, transportation or other charges incurred by you in connection with such repair or replacement.
2. To obtain the above remedy:
   - A. Immediately notify the G-R Unit upon discovery of the claimed defect in materials or workmanship and provide the serial number or date code of the product and/or part(s) or provide the G-R Unit with the invoice or bill of sale referencing the product by no later than the expiration date of the warranty period.
   - B. The G-R Unit will advise whether inspection will be necessary and how whether repair or replacement will be made. If inspection by the G-R Unit is necessary, the pump or defective part must be sent freight pre-paid to the G-R Unit. Return shipment will be F.O.B. the G-R Unit's plant.
   - C. **Return Goods Authorization Requirement:** No product will be accepted for return or replacement without the prior written authorization of the G-R Unit. Upon such authorization, and in accordance with instructions from the G-R Unit, the product will be returned to the G-R Unit, shipping charges prepaid by the Buyer.

3. **Damages:** The G-R Unit's liability for damages for breach of this Limited Warranty shall not exceed the amount of the purchase price of the product or part(s) in respect to which Such damages are claimed. **IN NO EVENT SHALL THE G-R UNITS BE LIABLE FOR INCIDENTAL, CONSEQUENTIAL OR SPECIAL DAMAGES FOR BREACH OF THIS LIMITED WARRANTY.**

Some states do not allow the exclusion or limitation of incidental or consequential damages, so the above limitation or exclusion may not apply to you. This Limited Warranty gives you specific legal rights, and you may also have other rights, which vary from state to state.

A Gorman-Rupp Company




BY

GORMAN-RUPP®

**www.amtpump.com**